



10965 Andrews Place
Fishers, IN 46037
1-800-589-PROS (7767)
(317) 813-3055
Fax (317) 813-3056
www.proplasticsusa.com

Chiller Preventative Maintenance

- Lubricate all motors. Note that some motors are supplied with sealed bearings.
- Check belt alignment, tension and condition
- Tighten all wire terminals.
- Clean and check motor starter and contactor contacts.
- Check safety switch settings.
- Clean condenser fins of dust and dirt.
- Back flush evaporator.
- Check glycol/water solution ratio for operating temperature.
- Check system for leaks.
- Check condition of air filters
- Check and clean Y-strainer
- Refrigerant sight glass: check for bubbles when compressor is operating at 100%.
Check the moisture indicator for a color other than green.
- Clean unit.

\$850 / PER DAY **

**** Does not include expenses (travel time and mileage).**